

DEPARTMENT OF PUBLIC HEALTH

WELL DATA (1) Place and Owner HOLMEWS ENGINEERING & DEVELOPMENT CORP. ASPENDELL TRACT 2 SIERRA ESTATES.

(2) Source of Information Field inspection & tests.

Collected by Gordon C. Holmes

Date 7-23-79

	1	2
(3) Number or Name		
Date drilled	August 1978	Not yet drilled
(4) Location: Neighborhood		
Size of lot		
Distance to: Sewer	100 feet	50 feet
Sewage disposal	area sewerd	area sewerd
Abandoned well	None	None
Nearest property line	5 feet	5 feet
(5) Housing: Type	Wood frame	unbuilt
Condition	New	
Pit depth (if any)	None	
Floor (material)	Concrete	
Drainage	gravity	
(6) Well Depth	80 feet	100 feet
(7) Casing: Depth	80 feet	100 feet
Diameter	8-inch	8-inch
Kind	PVC	PVC
Height above floor	6-inch	6-inch
Distance to highest perforations	40 feet	40 feet
Surface sealed (yes or no)	Yes	Yes
Gravel pack (yes or no)	Yes	Yes
Second casing depth		
Second casing diameter		
Annular seal (depth)		
(8) Impervious Strata: { Thickness	None	None
Penetrated { Depth to		
(9) Water Levels: { Surface	35 feet	35 feet
Depth to { Static	60 feet	60 feet
{ When Pumping		
(10) Pump: Make	Gould	Gould
Type	Submersible	Submersible
Capacity, g.p.m.	75	75
Lubrication		
Power	Electric	Electric
Auxiliary power	None	
Control	Float at reservoir	
Discharge location	To distribution system	
Discharge to		
(11) Frequency of Use	On demand	On demand
(12) Flood Hazard	None	None
(13) Remarks and Defects (Use other side if necessary)		

(14) Show well log on other side.